

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

DRINKING WATER WARNING

The City of San Juan Bautista Water System has high levels of nitrate

DO NOT GIVE THE WATER TO INFANTS UNDER 6 MONTHS OLD OR PREGNANT WOMEN OR USE IT TO MAKE INFANT FORMULA

Water sample results received from 12/1/2017 to 12/31/2017 showed nitrate levels ranging from 7.14 to 9.73 milligrams per liter. While these results do not exceed the nitrate standard, or maximum contaminant level (MCL), of 10 milligrams per liter, Nitrate monitoring results from June through November 2017 showed concentrations above the nitrate MCL. The City of San Juan Bautista is issuing this notice as a precaution because the water provided by the water system cannot be assured to reliably meet the nitrate MCL at all times. Nitrate in drinking water is a serious health concern for infants less than six months old.

What should I do?

- **DO NOT GIVE THE WATER TO INFANTS.** *Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. Symptoms in infants can develop rapidly, with health deteriorating over a period of days. If symptoms occur, seek medical attention immediately.*
- **PREGNANT WOMEN SHOULD NOT CONSUME THE WATER.** *High nitrate levels may also affect the oxygen-carrying ability of the blood of pregnant women.*
- Water, juice, and formula for children under six months of age should not be prepared with tap water. Bottled water or other water low in nitrates should be used for infants until further notice.
- **DO NOT BOIL THE WATER.** Boiling, freezing, filtering, or letting water stand does not reduce the nitrate level. Excessive boiling can make the nitrates more concentrated, because nitrates remain behind when the water evaporates.
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Nitrate in drinking water can come from natural, industrial, or agricultural sources (including septic systems, storm water run-off, and fertilizers). Levels of nitrate in drinking water can vary throughout the year. We will let you know when the amount of nitrate is again below the limit.

The City is working to bring two new wells into the water system so that Well #2 (high nitrates) can be taken off-line. The goal is to have the system back in compliance by November.

For more information, please contact The City of San Juan Bautista at 831-623-4661 or 311 Second Street (P.O. Box 1420), San Juan Bautista, CA 95045.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being posted by The City of San Juan Bautista.
State Water System ID#: 3510002. Date distributed: 1/9/2018.