

Quarterly Report for Disinfectant Residuals Compliance For Systems Using Chlorine or Chloramines

Attachment A

System Name: San Juan Bautista Water System

System No.: 3510002

Calendar Year: 2018

Quarter: 1,2,3,4

1st Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Year	April		
	May		
	June		
	July		
	August		
	September		
	October		
	November		
	December		
	Current Year	January	9 0.59
		February	8 0.60
		March	8 0.63
Running Annual Average (RAA):		0.61	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

2nd Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Year	July		
	August		
	September		
	October		
	November		
	December		
	Current Year	January	0.59
		February	0.60
		March	0.63
		April	8 0.42
		May	10 0.41
		June	8 0.37
Running Annual Average (RAA):		0.50	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

3rd Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Yr	October	
	November	
	December	
Current Year	January	0.59
	February	0.60
	March	0.63
	April	0.42
	May	0.41
	June	0.37
	July	8 0.56
	August	10 0.97
	September	7 0.79
Running Annual Average (RAA):		0.59
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

4th Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Current Year	January	0.59
	February	0.60
	March	0.63
	April	0.42
	May	0.41
	June	0.37
	July	0.56
	August	0.97
	September	0.79
	October	4 1.37
	November	4 0.79
	December	4 0.98
Running Annual Average (RAA):		0.71
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Comments:

Signature:

Date: 12/30/2018