



City of San Juan Bautista
 DDW
 311 2nd St.
 San Juan Bautista, CA 95045

4 Justin Court Suite D, Monterey, CA 93940
 831.375.MBAS (6227)
 www.MBASinc.com
 ELAP Certification Number: 2385

Wednesday, April 03, 2019

Lab Number: 190304_32-01

Collection Date/Time: 3/4/2019 8:49 Sample Collector: Madrigal, J Client Sample #:
 Submittal Date/Time: 3/4/2019 15:24 System ID: 3510002 Coliform Designation: Routine

Sample Description: City of San Juan Bautista, 80 Long St

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1	1	3/4/2019	16:30	MW
Coliform, Total	Colitag-24hr	MPN/100mL	Absent		1	1	3/4/2019	16:30	MW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	1.00		1	0.05	3/4/2019	8:49	

Comments:

Lab Number: 190319_16-02

Collection Date/Time: 3/19/2019 10:45 Sample Collector: Madrigal, J Client Sample #:
 Submittal Date/Time: 3/19/2019 12:03 System ID: 3510002 Coliform Designation: Routine

Sample Description: City of San Juan Bautista, 68 Polk St

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1	1	3/19/2019	15:30	OW
Coliform, Total	Colitag-24hr	MPN/100mL	Absent		1	1	3/19/2019	15:30	OW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	1.20		1	0.05	3/19/2019	10:45	

Comments:

Lab Number: 190325_25-01

Collection Date/Time: 3/25/2019 10:45 Sample Collector: Madrigal, J Client Sample #:
 Submittal Date/Time: 3/25/2019 15:21 System ID: 3510002 Coliform Designation: Routine

Sample Description: City of San Juan Bautista, City Maintenance Yard

Analyte	Method	Unit	Result	Qual	Dil.	PQL	Anal. Date	Anal. Time	Analyst
Coliform, E Coli	Colitag-24hr	MPN/100mL	Absent		1	1	3/25/2019	16:00	MW
Coliform, Total	Colitag-24hr	MPN/100mL	Absent		1	1	3/25/2019	16:00	MW
Chlorine Residual (Field)	SM4500-Cl G	mg/L	1.50		1	0.05	3/25/2019	10:45	

Comments:

Report Approved by: 
 David Holland, Laboratory Director

mg/L : Milligrams per liter (=ppm) µg/L : Micrograms per liter (=ppb) PQL : Practical Quantitation Limit MCL : Maximum Contamination Level
 H = Analyzed outside of hold time E = Analysis performed by External Laboratory; See Report attachments T = Temperature Exceedance
 MDL = Method Detection Limit J = Result is less than PQL ND = Non Detect